

ATTENTION

Hazardous Waste Storage Area

(Hazardous Waste in a Designated Accumulation Area)

Once hazardous waste leaves the satellite accumulation area and enters a different location, referred to here as an **accumulation area**, it is subject to more stringent management standards.

When waste leaves the satellite accumulation area, "the clock starts," and from this date, the waste must be shipped off-site to a permitted hazardous waste treatment, storage or disposal facility (TSDF) within 90, 180 or 270 days, depending on the generator's status (e.g., CESQG, SQG, or LQG) and distance from the TSDF (40 CFR § 262.34).

In the accumulation (storage) area, all hazardous waste containers **MUST**:

- ✓ Be clearly marked with the **date** they entered the area.
- ✓ All containers must be clearly marked "**hazardous waste**." Use a hazardous waste label.
- ✓ Emergency equipment such as fire extinguishers and absorbents must be maintained at the accumulation area.
- ✓ Post the Emergency Site Plan and Telephone List in the area.
- ✓ Waste containers must be arranged in the accumulation area so that there is adequate aisle space to allow for the flow of emergency personnel and equipment. Keep labels turned where visible from the outside of the aisle(s).
- ✓ Incompatible wastes must be separated to the extent possible using distance, berms or containment pans.
- ✓ The accumulation area **must be inspected weekly** for leaks and deterioration, and to ensure adequate spill response materials are on-hand.
- ✓ Hazardous Waste Flammables can be stacked only 2 high.
- ✓ Store hazardous waste no longer than 180 days (SQG) or 90 days (LQG).
- ✓ **Conduct and document weekly inspections** using the forms provided by Crandall Corporation.